



No Lesen : FL000028

Licence No :

SIJIL BARANGAN TERSENARAI *Product Listing Certificate*

**SIRIM QAS International Sdn. Bhd. dengan ini menganugerahkan kepada
*SIRIM QAS International Sdn. Bhd. hereby grants to***

**TROCELLEN S. E. A. SDN. BHD.
LOT 2213, KG BATU 9 KEBUN BARU
JALAN KASAWARI
TELOK PANGLIMA GARANG
42500 TELOK PANGLIMA GARANG
SELANGOR, MALAYSIA**

**Sijil untuk menggunakan Tanda Barangan Tersenarai
*a certificate to use the Listed Product Mark on***

POLYETHYLENE FOAM LAMINATED WITH ALUMINIUM FOIL

Please refer to detail in the SCHEDULE

**sebagai mematuhi keperluan
*as complying with***

**BS 476 : PART 6 : 1989 + A1 : 2009
BS 476 : PART 7 : 1997**

Nur Fadhilah binti Muhammad
Ketua Pegawai Eksekutif
Chief Executive Officer
SIRIM QAS International Sdn. Bhd.

SIRIM QAS International Sdn. Bhd.
(No. Syarikat 410334-X)
1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tel : 60-3-55446400
Faks : 60-3-55446466

<http://www.sirim.my>

<http://www.malaysian-certified.my>

Tarikh Mula Pensijilan : 16 March 2015

Certified Since

Sah Sehingga : 16 March 2022

Valid Until

Tarikh Dikeluarkan : 18 February 2021

Issue Date

No Siri : 061842

Serial No

Lesen ini dianugerahkan tertakluk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.

SCHEDULE



SIRIM

TROCELLEN S. E. A. SDN. BHD.

Trade Mark : TROCELLEN PRO
 Model : 2506W3CF2 733 + ALU, 2508W3CF2 733 + ALU
 Rating : Foam Density: 25 kg/m³ Fire Propagation Index: 9.9, 7.6 Surface Spread of Flame: Class One
 Type : Polyethylene foam with facing material : Aluminium Foil
 Size : Nominal Thickness: 6 mm, 8 mm
 Test report no.: 2014FE0307, 2014FE0303, 2014FE0306, 2014FE0302

Trade Mark : TROCELLEN PRO
 Model : 2506W3CF4 733 + ALU-S, 2512W3CF4 733 + ALU-S, 2530W3CF4L 733 + ALU-S
 Rating : Foam Density: 25 kg/m³ Fire Propagation Index: 5.6, 4.0, 7.7 Surface Spread of Flame: CLASS ONE
 Type : Polyethylene foam with facing material : Aluminium Foil
 Size : Nominal Thickness: 6mm – 30mm
 Test report no.: 2016FE0108, 2016FE0109, 2016FE0107, 2016FE0105, 2016FE0253, 2016FE0254

Trade Mark : TROCELLEN PRO
 Model : 3305NF4 775 + ALU-S, 3310NF4 775 + ALU-S, 3312NF4 775 + ALU-S
 Rating : Foam Density: 33 kg/m³ Fire Propagation Index: 6.9, 8.5, 5.9 Surface Spread of Flame: CLASS ONE
 Type : Polyethylene foam with facing material : Aluminium Foil
 Size : Nominal Thickness: 5mm – 12mm
 Test report no.: 2016FE0102, 2016FE0103, 2016FE0100, 2016FE0101, 2016FE0252, 2016FE0099

Trade Mark : TROCELLEN PRO
 Model : Trocellen Pro – AirPro Plus
 Rating : Foam Density: 25 kg/m³ Fire Propagation Index: 6.6, 7.5, 9.8 Surface Spread of Flame: CLASS ONE
 Type : Polyethylene foam with facing material : Aluminium Foil
 Size : Nominal Thickness: 6mm – 30mm
 Test report no.: 2018FE0590, 2018FE0591, 2018FE0675, 2018FE0676, 2019FE0449, 2019FE0450



No Lesen : FL000028

Licence No :

SCHEDULE



SIRIM

TROCELLEN S. E. A. SDN. BHD.

Trade Mark : TROCELLEN PRO
Model : Trocellen Pro – HeatPro
Rating : Foam Density: 33 kg/m³ Fire Propagation Index: 9.5, 7.3, 9.0, 9.8 Surface Spread of Flame: CLASS ONE
Type : Polyethylene foam with facing material : Aluminium Foil
Size : Thickness: 5mm – 30mm
Test report no.: 2020FE0157, 2020FE0158, 2020FE0159, 2020FE0160, 2020FE0161, 2020FE0162, 2020FE0163, 2020FE0164

TEST REPORT NO. : 2014FE0307, 2014FE0303, 2014FE0306, 2014FE0302, 2016FE0108, 2016FE0109, 2016FE0253, 2016FE0107, 2016FE0254, 2016FE0105, 2016FE0102, 2016FE0103, 2016FE0100, 2016FE0101, 2016FE0252, 2016FE0099, 2018FE0590, 2018FE0591, 2018FE0675, 2018FE0676, 2019FE0449, 2019FE0450, 2020FE0157, 2020FE0158, 2020FE0159, 2020FE0160, 2020FE0161, 2020FE0162, 2020FE0163, 2020FE0164

End of page

SIRIM QAS International Sdn. Bhd.
(No. Syarikat 410334-X)
1, Persiaran Dato' Menteri
Seksyen 2, Peti Surat 7035
40700 Shah Alam
Selangor Darul Ehsan
MALAYSIA.

Tarikh Mula Pensijilan : 16 March 2015

Certified Since

Sah Sehingga : 16 March 2022

Valid Until

Tarikh Dikeluarkan : 18 February 2021

Issue Date

No Siri : 061842

Serial No

Tel : 60-3-55446400
Faks : 60-3-55446466

<http://www.sirim.my>

<http://www.malaysian-certified.my>

Lesen ini dianugerahkan tertakuk kepada syarat-syarat Perjanjian Pensijilan Barangan SIRIM QAS International Sdn. Bhd.
This Licence is granted subject to the provisions of the Product Certification Agreement of SIRIM QAS International Sdn. Bhd.