

Emission Test Certificate

Friday, 5th January 2018

Supplier: Trocellen S.E.A Sdn. Bhd. (Lot 2213, Batu 9, Kebun Baru, Jalan Kasawari, Telok Panglima Garang, Selangor, 42500, Malaysia.)

Sample Description: Trocellen Polyethylene Foam 3025W3CF4L 733

Date Tested: January 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-10 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs exposure):

| | |
|---|--|
| <p>Green Building Council of Australia Green Star Design and As Built v1.1 - 13.1.2B</p> | <p>Trocellen Polyethylene Foam 3025W3CF4L 733</p> |
| <p>Total Volatile Organic Compound Emission Rate limit <0.5 mg/m²/hr</p> | <p>Total Volatile Organic Compound Emission Rate: 0.018 mg/m²/hr</p> |
| <p><i>The Total Volatile Organic Compounds emission of this material are well below 0.5 mg/m²/hr at 24 hrs as specified by GBCA’s Green Star Design & As Built V1.1 - 13.1.2B. Therefore, this product can be classed as “low VOC emitting”.</i></p> | |



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

CV171246